

Frequency Comb


Setup

Typical Values



Achtung: Gemessene Werte enthalten auch andere Wellenlängen!!! Es wurde nur mit dem Thorlabs-Power-Meter die Wellenlängen verändert, dieses aber nicht selektieren kann! Daher wird gleichzeitig >600nm Licht gemessen.
Gemessene Werte im Januar 2017

- Laser diode current: 9.0
- AC: 950, DC: 850 (in Fiber laser software)
- Powers:
 - after fiber laser: ~ 200 mW @ 1560 nm
 - after SHG:
 - ~ 35-40 mW @ 780 nm
 - ~ 95 mW @ 1550 nm
 - direct after filter:
 - ~ 32 mW @ 780 nm
 - direct infront PCF:
 - ~ 300 mW @ 780 nm without filter
 - ~ 20 mW @ 780 nm with filter
 - ~ 8 mW @ 1550 nm without filter
 - after PCF:
 - ~ 8.5 mW @ 780 nm without filter (red light should be visible)
 - ~ 1.8 mW @ 780 nm with filter
 - ~ 250 μ W @ 1550 nm without filter
- Clock Laser / DUT ~ 5 mW; FWHM $\ll$ 100 MHz
- (right picture is an old measurement and we don't know where in the comb)
- CEO frequency has a linewidth of ~500kHz
 - yellow = good lock
 - white = bad lock, because the platform and width



Electronic part



Attention: The pump diode current must not be set higher than **>9.5 (=950mA)**!
Never set the pump diode current to 10.0 (=1000mA = max. current of the pump diodes)!


Reprate

Repraten Aufbau ab Oktober 2018

<color #ff00ff>Siehe Foto</fc>

- DXD200 Phase Detector:
 - Lock on
- PIC201 Lockbox
 - Offset on
 - Invert on

Repraten Aufbau bis Oktober 2018



- Die Reprate kommt vom Synthesizer: $10 \cdot f_{\text{rep}}$
- $10 \cdot f_{\text{rep}}$ geht in die Reprate-Box [A] IN

- Photodioden Signal des Frequenzkammes von "RF OUT" in die Reprate-Box [B] IN
- Dort wird [A] und [B] gemixt und intern zum "OUT" geschickt
- Der Beat [C] zwischen [A] und [B] wird zum Teiler [D] geschickt und /16 geteilt [E]
- [E] wird zum Counter geschickt
- [F] wird zum Reprate-PID geschickt
- Der Beat zwischen der 10. Harmonischen von der Photodiode mit $10 \cdot f_{\text{rep}}$ ist 0 und wird als Fehlersignal benutzt
- Rapraten PID steuert Piezo im Resonator (Länge: 1.5m ~ FSR= 100MHz)
- Reprate ist fouriertransformiert der zeitliche Abstand zwischen zwei Pulsen

Turn off and on



- Turn off the frequency comb:
 1. Push Amplifier button (LED off)
 2. Push Laser button (LED off)
 3. turning the upper key (position 0)
 4. turning the lower key (position 0)
- Turn on:
 1. exactly the other way around

Regular problems

- Comb has to be optimized almost every day: Most of the times just tuning potis @ SHG & PCF is enough (see picture)



- Fiberlaser software does not start: Maybe wrong COM Port: Change @ Windows Device Manager
- FiberLaser software starts, but Fiber Comb does not: Maybe NI card not attached properly

- You can't lock CEO and Reprate, than restart the hole lasersysteme [probable all ~1-2 months].


Irregular problems

- Low power in general: Maybe pump diodes should be exchanged
 - 15.09.2016: 145 mW Output @ 9.5
 - Last change 12/2019
- No modelock possible
 - Decreasing of resonator coupling of comb. Noticed so far, if there was a failure of the air conditioning system:
 - Alignment of resonator
 - Manual:
[optimizing_mirror_alignment_for_m-comb_neu_v1.3_npe.pdf](#)
 - Additional information:
 - Die Steuersoftware sieht anders aus, sie tut jedoch das selbe wie die in der Anleitung abgebildete Fiberlaser0.9.6.
 - Der automatische Modelocksuche („relock“) bei Modelockverlust muss deaktiviert werden:
 - Die Spiegeljustage muss im nicht-modengekoppelten Zustand bei fixen Wellenplatten erfolgen.
 - Dabei läuft der Laser im CW-Betrieb.
 - Verstärker dürfen dabei nicht eingeschaltet werden.
 - Es wird auf die Ausgangsleistung des Freistrahlsports optimiert.
 - Eine Spiegeljustage nur anhand der DC-Werte ist auch möglich, jedoch ist die Auflösung und Reaktionszeit eines Powermeters in der Regel besser.

Output Ports

1064 Port


Data under ResLab: D:\Dokumente\Daten\Frequenzkamm\Spektren 161115 1064 nm Port.




Rf-output-fiber

- measured with optical spectrum analyzer from AG-Morgner
- Resolution: for peak 0.2nm and full range measurement 1.5nm
- pdf-files:

frequency_comb_spectrum_rf-fiber-output.pdf
frequency_comb_spectrum_rf-fiber-output_full_range_.pdf








Manuals and Datasheets

- Software for [FiberLaser](#)
- Software for [Fiber Comb Control](#)


Pictures from the inside of the frequency comb






















From:
<https://iqwiki.iqo.uni-hannover.de/> - IQwiki

Permanent link:
<https://iqwiki.iqo.uni-hannover.de/doku.php?id=groups:mg:private:resonatoren:comb:start&rev=1710927339>

Last update: 2024/03/20 09:35

